




America

CERTIFICATE

No. U8 15 05 92230 001

Holder of Certificate: **Chiltrix, Inc.**
732E Eden Way North 255
Chesapeake VA 23320
USA

Certification Mark:



Product: **Heat pump
(Air source heat pump)**

The product was voluntarily tested according to the relevant safety requirements noted above. It can be marked with the certification mark above. The mark must not be altered in anyway. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC Guide 67. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited certification body.

Test report no.: 64171110365202A

Valid until: 2016-05-19

Date, 2015-06-01

Page 1 of 2





America

CERTIFICATE
No. U8 15 05 92230 001

Model(s): CX30, CX45

Brand Name: Chiltrix

Parameters:

Rated Voltage:	240V
Rated Frequency:	60Hz
Rated Current:	
CX30	10,90A(cooling); 8,80A(heating)
CX45	19,20A(cooling); 14,10A(heating)
Refrigerant:	R410a,2.65kg for CX30
	R410a,2.9kg for CX45

Tested according to: UL 1995:2011/R:2014-10
 CSA C22.2 No.236:2011/R:2014-10

Production Facility(ies): 79711